

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3550-0610:129 Page 1 of 1

CATEGORY: Door Closer/Holders/Releasing Devices

LISTEE: Dorma Door Controls, PO Box AC, Reamstown PA 17567-0411
Contact: Rick Loose (717) 336-3881 FAX (717) 336-2106

DESIGN: Models 7601 EMR, 7601 EMF, 7605 EMR, 7605 EMF, 8901 EMR, 8901 EMF, 8905 EMR, 8905 EMF, TS93-1 EMR, TS93-1 EMF, TS93-5 EMR, TS93-5 EMF with suffix letters "T" (pull side mount), "PT" (push side mount), "DE" (double egress mount) with/without listed integral smoke detector. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as door closers/holders. May be connected to detection devices separately listed for releasing device service when connected to a separately listed fire alarm control unit.

05-10-01



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 21, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**